

**Intel New Mexico  
Community Environmental Working Group  
July 2010 EHS Activity Report**

**PLANT STATUS:**

Production equipment servicing Fab 11X was operating at approximately 95.3% of capacity (note this capacity was incorrectly reported as 100% for May and June).

**MONITORING UNDERWAY OR COMPLETED THIS MONTH:**

- Annual HAP testing completed 6/15 and test report submitted to NMED 7/8.
- Q2 Quarterly VOC testing completed 6/15 and test report submitted to NMED 7/8.
- Q3 VOC test schedule begins next week. Munters and Bridge Durr testing 7/22 - 8/20, and Fab Durr testing 9/7 - 9/22.

**INSPECTIONS/MEETINGS:**

- None

**SITE EVENTS :**

<b>Date:</b>	<b>Event:</b>	<b>Status/Community Impact:</b>
6/9/10	Emergency generator Start-up along the east side of the facility.	Odor, visual and possible increase in noise.
6/23/10	Concrete pour from 0100 to 0900 on the northwest side of the CUB.	Visual and possible increase in noise.
7/6/10-8/18/10	Crane activity along the north side of the CUB from July 6 <sup>th</sup> through August 18 <sup>th</sup> aiding in the construction of the ammonia treatment system.	Visual and possible increase in noise.
6/16/10	F11X Munters Unit 1 and 3 (VOC-138-1-120, VOC-138-3-120)	#3 down for maintenance, and #1 failed due to clogged air filter. #3 recovered and replaced air filters on #1. VOC emissions 1.66 lbs

**INFORMATION REQUESTED BY OR PROVIDED TO REGULATORY AGENCIES:**

<b>Item:</b>	<b>Permit or Regulatory Requirement/ Regulatory Request:</b>
Equipment downtime F11X F11X Munters Unit 1 and 3 (VOC-138-1-120, VOC-138-3-120)	Permit Requirement
Public Notice to Neighbors for Munters Permit Revision	Permit Requirement
Toxic Release Inventory Report Submittal	Regulatory Requirement

**CALLS RECEIVED: NUMBER OF NEIGHBORS CALLING IN – 1**

<b>Date</b>	<b>Comment</b>	<b>Action Taken</b>
6/15/2010	Neighbor in Zone 2 reported at 10:28 reported a puff of hot metal	All systems operating normally and no unusual conditions or activities.
6/25/2010	Neighbor in Zone 2 reported at 09:14 puff of powdered laundry detergent.	All systems operating normally and no unusual conditions or activities.
6/25/2010	Neighbor in Zone 1 reported at 17:12 puff of powdered laundry detergent.	All systems operating normally and no unusual conditions or activities.
6/28/2010	Neighbor in Zone 2 reported at 22:00 in the Sunflower Market parking lot, Alameda/528/Coors: hot metal odor.	All systems operating normally and no unusual conditions or activities.
7/5/2010	Neighbor in Zone 2 reported at 20:42 reported a strong hot metal odor.	All systems operating normally and no unusual conditions or activities.
7/5/2010	Neighbor in Zone 2 reported at 21:29 reported a hot metal odor along Loma Larga.	All systems operating normally and no unusual conditions or activities.